

District Level Water Testing Laboratory P.H.Division, Bettiah

PUBLIC HEALTH DIVISION, BETTIAH

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES

SAMPLE COLLECTED ON 04/06/2026 BY Principal & RECEIVED IN THE LABORATORY ON 04/06/2026

SAMPLE COLLECTED ON _____ BY _____ & RECEIVED IN THE LABORATORY ON _____																			
Sl. NO	PARTICULARS OF THE SAMPLE				PARAMETERS EXAMINED (VALUE IN Mg/L except pH. Otherwise Mentioned)														
	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Fluoride	T.D.S	Arsenic	Bacteriological test
1.	Narkatiya gang	Sathi	Sathi	Katahari Public School	1.0	7.2	253	96	104	24	8	16	10	0.2	0.0	0.2	169	NT	Neg
Min-Max Permissible Limit (IS:10500/2012)					1-5 NTU	6.5-8.5		200-600	200-600	75-200	30-100	250-1000	200-400	1.0-400	45-1.5	1-2.0	500-2000	0.01-0.05	+VE/-VE
Remarks- Analysed parameters of above sample are within permissible limits.																			

Remarks- Analysed parameters of above sample is within permissible limit.

Memo No.: 01 dated: 06.06.2026

Anil Kumar
06/06/2026
CHEMIST
DLWTL
P.H. Division, Bettiah